

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Sup./CHC/PPS/Inst/03

Dated: 18/04/24

It is certified that an inspection team headed by Dr Pawan Kumar
(Name of Officers with designation) from Community Health Centre, inspected the Prem Public School, Isauli Road, Near Roadways Bus Stand, Jalesar, Etah (Name & Address of the school) on 15/04/2024 (date of inspection) and on the basis of Water Test Report(Attached) bearing no 001 dated 16/04/2024 of **Officer Of Executive Engineer, Jal Nigam (Gramin), Etah, Up (UP JAL NIGAM)** certified that the Prem Public School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 17/04/25.

Signature with Seal:

[Signature]

Name: Dr. Pawan Kumar

अधीक्षक
सामुदायिक स्वास्थ्य केंद्र
जलेसर, एटा

Designation: M.S.

Name & Address of the Office / Department : NACH BAZAR

JALESAR ETAH.

To
Prem Public School,
Isauli Road, Near Roadways Bus
Stand, Jalesar, Etah



Office of Executive Engineer, Jal Nigam
(Gramin) Etah U.P.
Analysis Report of Water

To,

Report No.001

Place/Source of Samplin-SAMAR/ Prem Public school jalesar

Village Name- jalesar

Block- Jalesar

District- Etah


Name of Sample Collector- - Navin kant goyal Date/Time- 15-04-2024 02:00 pm

Date of Analysis- 16-04-2024

Latitude-

Longitude-

S. No.	Parameter (Unit)	BIS Acceptable Limit	Unit Mg/l	BIS Permissible Limit in Absence of alternate source	Result	Remarks
1	Turbidity	1.0	NTU	5	1.48	
2	pH	6.5-8.5	-	No Relaxation	7.05	
3	Chloride	250	Mg/l	1000	96	
4	TDS	500	Mg/l	2000	408	
5	Alkalinity	200	Mg/l	600	98	
6	Fluoride	1	Mg/l	1.5	0.5	
7	Nitrate	45	Mg/l	No Relaxation	3.12	
8	Sulphate	200	Mg/l	400	66	
9	Total Hardness	200	Mg/l	600	152	
10	Iron	1	Mg/l	No Relaxation	0.1	
11	Total Arsenic	0.01	Mg/l	No Relaxation	0.0	
12	Calcium	75-200	Mg/l		82	
13	Magnesium	30-100	Mg/l		70	
14	Colour	5-15	Hazen Unit		5	
15	Odour	-	-		Odourless	
16	Taste	-	-		Sweet	
17	Total Coliform			Shall not be Detectable in any 100 ml Sample	Not Detected	
18	E.coli			Shall not be Detectable in any 100 ml Sample	Not Detected	


Authorised Signatory
U.P Jal Nigam (Etah)